

CleanPipe™ jointing guidance

Using CleanPipe™ in trenchless installations



1 Attach the towing head directly to the leading end of the pipe coil. This operation is undertaken without removing the CleanPipe™ seals, located internally, a short distance from the pipe ends.



2 The pipe remains sealed throughout the whole installation procedure. Contamination from the installation process remains outside the factory seal.



3 After the installation is complete, CleanPipe™ can be pressure tested without the need to fit end caps. De-pressurise the pipeline before cutting the pipe ends.



4 Cut the pipe ends beyond the arrows which identify the cutting position on the label. This removes the seals, ready for the pipe to be joined using Radius Systems' fittings.



5 Prepare the pipe ends following the ProFuse® pipe preparation for electrofusion jointing above. Follow industry best practice and water industry procedures to make the joint and cleanse and test the pipeline.

